


Telephone No - 0474 2994773  
 E-mail - qcdkollam@gmail.com



**QUALITY CONTROL DISTRICT LABORATORY  
 KERALA WATER AUTHORITY  
 CANTONMENT P O, KOLLAM - 691 001**

**REPORT ON ANALYSIS OF WATER**

Report No - 2024/QCDKLM/325		Date: 20/01/2024		
Customer Name & Address		1. Date of Sample received: 17/01/2024		
<p align="center"><b>THE PRINCIPAL,          MANNAM MEMORIAL          RESIDENTIAL PUBLIC SCHOOL,          VALATHUNGAL,          VALATHUNGAL.P.O.          KOLLAM - 691 011          9605913604</b></p>		2. Sampling done by: Customer		
		3. Sample Quantity : 250 ml		
		4. Source of Sample : Open Well Water		
		5. Sample Code : 2024/QCDKLM/325		
		6. Test Performing Dates		
		From : 17/01/2024 To : 20/01/2024		
Sl. No.	Parameters	Acceptable limits as per IS 10500 - 2012	Test Method	Result
1	Total Coliforms/ 100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT
2	E. coli /100 ml	Shall not be detected/100 ml	IS 15185 : 2016	ABSENT


NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.


Authorized By 

**BACTERIOLOGIST  
 QUALITY CONTROL DISTRICT LAB  
 KERALA WATER AUTHORITY  
 KOLLAM**

\* End of Report \*

KWA/KLM/R/19 Issue No. 01 Issue Date: 06.01.2024 Rev.No. 00 Rev. Date: 00

  
**MANAGER  
 MANNAM MEMORIAL**

  
**PRINCIPAL  
 Mannam Memorial Residential  
 Public School**